MARK	MAX. AIRFLOW	MIN. AIRFLOW	UNOCCUPIED AIRFLOW (CFM)	TERMINAL		HOT WATER HEATING COIL PERFORMANCE						DESIGN	
MARK	(CFM)	(CFM)	(CFM) (NOTE 3)	TYPE (NOTE 2)	CAPACITY (MBH)	COIL FLOW (GPM)	AIR TEMP. RISE (*F)	WATER PRES. DROP (FT.)	AIR PRES. DROP (WG)	NUMBER OF ROWS	CODE/ STANDARD	SPACE DESCRIPTION	MINIMUM REQUIREMEN
VAV-1	350	150	<b>A</b> -	Α	7.0	1.0	43	0.5	0.06"	1	ASHRAE 62.1	OFFICE	CFM OA
/AV-2	400	100	_	В	6.9	1.0	64	0.69	0.07"	1	ASHRAE 62.1	OFFICE	CFM OA
′AV-3	1000	500	_	С	17.0	2.0	31.5	0.68	0.18"	1	ASHRAE 62.1	OFFICE	CFM OA
/AV-4	250	250	_	Α	8.6	1.0	32	0.5	0.05"	1	ASHRAE 62.1	CORRIDOR	CFM OA
/AV-5	350	200	100	Α	7.7	1.0	35.5	0.5	0.09"	1	2010 FGI	DIAGNOSTIC	2/6 ACH
/AV-6	150	100	50	Α	5.9	1.0	54.5	0.5	0.02"	1	2010 FGI	DIAGNOSTIC	2/6 ACH
'AV-7	350	200	100	Α	7.7	1.0	35.5	0.5	0.09"	1	2010 FGI	DIAGNOSTIC	2/6 ACH
AV-8	150	100	50	Α	5.9	1.0	54.5	0.5	0.02"	1	2010 FGI	DIAGNOSTIC	2/6 ACH
'AV-9	350	200	100	Α	7.7	1.0	35.5	0.5	0.09"	1	2010 FGI	DIAGNOSTIC	2/6 ACH
V-10	250	100	_	Α	5.9	1.0	54.5	0.5	0.02"	1	ASHRAE 62.1	OFFICE	CFM OA
V-11	150	150	_	Α	7.0	1.0	42.8	0.5	0.02"	1	2010 FGI	SOILED	2/6 ACH
4V-12	450	250	125	В	12.8	1.0	47	0.69	0.09"	1	2010 FGI	DIAGNOSTIC	2/6 ACH
AV-13	3000	3000	_	F	88.5	3.0	27	0.5	0.51"	2	2010 FGI	WAITING	2/12 ACH
AV-14	300	200	_	Α	7.7	1.0	35.5	0.5	0.09"	1	ASHRAE 62.1	OFFICE	CFM OA
4V-15	1050	575	_	С	18.1	2.0	28.9	0.68	0.07"	1	ASHRAE 62.1	OFFICE	CFM OA
4V-16	500	500	_	В	21.9	1.0	40.5	0.33	0.2"	2	ASHRAE 62.1	OFFICE	CFM OA
¥V−17	300	200	_	Α	7.7	1.0	35.5	0.5	0.09"	1	ASHRAE 62.1	CORRIDOR	CFM OA
4V-18	300	200	_	A	7.7	1.0	35.5	0.5	0.09"	1	ASHRAE 62.1	CORRIDOR	CFM OA
¥V−19	1300	400	200	D	16.0	2.0	37	0.88	0.2"	1	2010 FGI	DIAGNOSTIC	2/6 ACH
V-20	360	360	_	В	11.6	2.0	31.5	2.34	0.07"	1	2010 FGI	DIAGNOSTIC	2/6 ACH
AV-21	250	200	_	Α	7.7	1.0	35.5	0.5	0.05"	1	2010 FGI	DIAGNOSTIC	2/6 ACH
¥V−22	500	200	_	В	9.2	1.0	42.5	0.69	0.1"	1	2010 FGI	LAB NUC ME	2/6 ACH
AV-23	500	200	100	В	9.2	1.0	42.5	0.69	0.1"	1	2010 FGI	DIAGNOSTIC	2/6 ACH
/AV-24	500	200	100	В	9.2	1.0	42.5	0.69	0.1"	1	2010 FGI	DIAGNOSTIC	2/6 ACH
'AV-25	200	100	_	Α	5.9	1.0	54.5	0.5	0.03"	1	2010 FGI	DIAGNOSTIC	2/6 ACH
¥V−26	1200	200	_	С	-	_	_	-	-	-	ASHRAE 62.1	STORAGE	CFM OA
4V-27	250	250	<u> </u>	Α	8.6	1.0	32	0.5	0.05"	1	2010 FGI	DIAGNOSTIC	2/6 ACH
AV-28	600	350	175	В	11.4	1.0	30	0.69	0.14"	1	2010 FGI	DIAGNOSTIC	2/6 ACH
AV-29	100	100	_	Α	5.9	1.0	54.1	0.5	0.01"	1	2010 FGI	CLEAN	2/4 ACH
AV-30	450	250	125	В	12.8	1.0	47	0.69	0.09"	1	2010 FGI	DIAGNOSTIC	2/6 ACH
'AV-31	450	150	_	В	8.0	1.0	49	0.69	0.02"	1	ASHRAE 62.1	OFFICE	CFM OA
AV-32	200	200	_	Α	7.7	1.0	35.3	0.5	0.02"	1	2010 FGI	SOILED	2/6 ACH
	200	200	_	Α	7.7	1.0	35.3	0.5	0.02"	1	2010 FGI	HOLDING RM	2/6 ACH
₩-33	1300	400	200	D	16.0	2.0	37	0.88	0.2"	1	2010 FGI	DIAGNOSTIC	2/6 ACH

## GENERAL COMMISSIONING NOTES:

- A. SEE SPECIFICATION SECTION 019100 GENERAL COMMISSIONING REQUIREMENTS FOR COMMISSIONING SCOPE AND REQUIREMENTS.
- B. THE MECHANICAL CONTRACTOR, TEMPERATURE CONTROLS CONTRACTOR, AND BALANCING CONTRACTOR WILL WORK WITH THE COMMISSIONING AGENT TO COMPLETE THE PREFUNCTIONAL AND FUNCTIONAL TESTING AND VERIFICATION.
- C. FULL FUNCTIONAL TESTING (INCLUDING SENSOR CALIBRATION AND AIR/WATER BALANCING) SHALL BE PERFORMED ON ÀLL VAV BOXES. CX AGENT, TAB CONTRÁCTOR AND CONTRÓLS CONTRACTOR WILL WORK TOGETHER DURING FUNCTIONAL TESTING OF VAV BOXES.

VAV TERMINAIS (VAV)

	VAV	IERMI	NALS											
	MARK	MAX. AIRFLOW	MIN. AIRFLOW	TERMINAL TYPE	HOT WATER HEATING COIL PERFORMANCE							DESIGN		
	WIZINI	(CFM)	(CFM)	(NOTE 2)	CAPACITY (MBH)	COIL FLOW (GPM)	AIR TEMP. RISE (*F)	WATER PRES. DROP (FT.)	AIR PRES. DROP (WG)	NUMBER OF ROWS	CODE/ STANDARD	SPACE DESCRIPTION	MINIMUM REQUIREMENT	
	VAV-35	300	100	A	9.4	2.0	34	1.7	0.05"	1	ASHRAE 62.1	CORRIDOR	CFM OA	
	VAV-36	500	100	В	_	_	_	-	-	_	ASHRAE 62.1	STORAGE	CFM OA	
	VAV-37	225	100	A	8.2	1.0	33	0.5	0.04"	1	ASHRAE 62.1	OFFICE	CFM OA	
	VAV-38	200	100	Α	5.9	1.0	54.1	0.5	0.01"	1	ASHRAE 62.1	OFFICE	CFM OA	
	VAV-39	200	100	Α	5.9	1.0	54.1	0.5	0.01"	1	ASHRAE 62.1	OFFICE	CFM OA	
	VAV-40	600	350	В	11.5	1.0	30.1	0.69	0.06"	1	ASHRAE 62.1	DRESSING	CFM OA	
	VAV-41	175	75	Α	7.0	1.0	43	0.5	0.02"	1	ASHRAE 62.1	OFFICE	CFM OA	
	VAV-42	325	50	А	5.9	1.0	54	0.5	0.01"	1	ASHRAE 62.1	OFFICE	CFM OA	
	VAV-43	125	50	Α	5.9	1.0	54	0.5	0.01"	1	ASHRAE 62.1	OFFICE	CFM OA	
	VAV-44	125	50	Α	5.9	1.0	54	0.5	0.01"	1	ASHRAE 62.1	OFFICE	CFM OA	
	VAV-45	425	200	В	20.1	1.0	46	0.33	0.13"	2	ASHRAE 62.1	OFFICE	CFM OA	
	VAV-46	125	50	Α	5.9	1.0	54	0.5	0.01"	1	ASHRAE 62.1	OFFICE	CFM OA	
	VAV-47	125	50	Α	5.9	1.0	54	0.5	0.01"	1	ASHRAE 62.1	OFFICE	CFM OA	
	VAV-48	260	75	Α	6.4	1.0	47	0.5	0.015"	1	ASHRAE 62.1	OFFICE	CFM OA	
	VAV-49	260	75	Α	7.0	1.0	43	0.5	0.02"	1	ASHRAE 62.1	OFFICE	CFM OA	
	VAV-50	260	75	A	6.4	1.0	47	0.5	0.015"	1	ASHRAE 62.1	OFFICE	CFM OA	
2	VAV-51	460	150	В	8.0	1.0	49	0.69	0.02"	1	ASHRAE 62.1	OFFICE	CFM OA	
	VAV-52	225	100	A	5.9	1.0	54	0.5	0.01"	1	ASHRAE 62.1	LOUNGE	CFM OA	
	VAV-53(	260	75	Α	6.4	1.0	47	0.5	0.015"	1	ASHRAE 62.1	OFFICE	CFM OA	
	VAV-54	150	75	А	7.0	1.0	43	0.5	0.02"	1	ASHRAE 62.1	OFFICE	CFM OA	
	VAV-55(	275	100	Α	8.2	1.0	33	0.5	0.04"	1	ASHRAE 62.1	OFFICE	CFM OA	
2	VAV-56	475	200	В	20.1	1.0	46	0.33	0.13"	2	ASHRAE 62.1	OFFICE	CFM OA	
	VAV-57	200	100	Α	7.7	1.0	35	0.5	0.03"	1	ASHRAE 62.1	OFFICE	CFM OA	
	VAV-58(	260	75	Α	5.9	1.0	54	0.5	0.01"	1	ASHRAE 62.1	OFFICE	CFM OA	
2	VAV-59	260	50	Α	5.9	1.0	54	0.5	0.01"	1	ASHRAE 62.1	OFFICE	CFM OA	
	VAV-60	1100	1100	D	44	3.0	37	1.9	0.23"	2	ASHRAE 62.1	OFFICE	CFM OA	
	VAV-61	225	100	А	8.2	1.0	33	0.5	0.04"	1	ASHRAE 62.1	OFFICE	CFM OA	
	VAV-62	500	300	В	29	2.0	38	1.3	0.36"	2	ASHRAE 62.1	OFFICE	CFM OA	
	VAV-63	125	50	А	5.9	1.0	54	0.5	0.01"	1	ASHRAE 62.1	OFFICE	CFM OA	
	VAV-64	150	50	А	7.0	1.0	43	0.5	0.02"	1	ASHRAE 62.1	COPY/WORK	CFM OA	
	VAV-65	250	100	Α	9.4	2.0	34	1.7	0.05"	1	ASHRAE 62.1	OFFICE	CFM OA	
2	VAV-66	260	75	Α	7.0	1.0	43	0.5	0.02"	1	ASHRAE 62.1	OFFICE	CFM OA	
	VAV-67	260	75	Α	7.0	1.0	43	0.5	0.02"	1	ASHRAE 62.1	OFFICE	CFM OA	
	VAV-68	260	75	Α	7.0	1.0	43	0.5	0.02"	1	ASHRAE 62.1	OFFICE	CFM OA	
		$\overline{}$	•								1			

**VAV TERMINAL NOTES:** 

NOTE 1: BASIS OF SPECIFICATION SHALL BE CAPABLE OF OPERATING WITH A MINIMUM INLET PRESSURE OF 0.5 IN. W.G. PROVIDE WITH SCREW ACCESS (UN-HINGED) WHERE TERMINALS ARE INSTALLED IN THE BEAM/JOIST SPACE.

NOTE 2: REFER TO "VARIABLE AIR VOLUME TERMINALS: CONNECTION SCHEDULE" FOR TERMINAL SIZE, DUCT CONNECTIONS AND DUCT SIZES.

VARIABLE AIR VOLUME TERMINALS : CONNECTION SCHEDULE

	IN	LET	MAX AIRFLOW	TERMINAL	RADIATED NOISE	DISCHARGE		
TERMINAL TYPE	TERMINAL NECK SIZE (IN)	SUPPLY DUCT (IN)	(CFM)	AIR PRESSURE DROP (IN W.G.)	(NC)	TERMINAL CONN. SIZE (IN)	DISCHARGE DUCT (IN)	
A	6 <b>"</b> ø	8"ø	350	1.0"	25	12x8	10x10	
В	8 <b>"</b> ø	10 <b>"</b> ø	700	1.0"	27	12x10	16x12	
С	10 <b>"</b> ø	12 <b>"</b> ø	1200	1.0"	28	14x12.5	22×12	
D	12 <b>"</b> ø	14"ø OR 16x10	1600	1.0"	30	16x15	26×12	
E	14 <b>"</b> ø	18×12	2400	1.0"	30	20x18	30×12	
F	16 <b>"</b> ø	24x12	3200	1.0"	25	24x18	34x14	

- 1. PROVIDE DUCT SIZES AS INDICATED OR EQUIVALENT FREE AREA AS INDICATED ON PLANS.
- 2. PROVIDE FLEXIBLE DUCT CONNECTORS ON SUPPLY DUCTWORK CONNECTION POINT.
- 3. CONTRACTOR SHALL PROVIDE ALL TRANSITIONS/OFFSETS AS NECESSARY.

EXHAUST FANS

MARK	EF-1
STYLE	UTILITY VENT SET
TYPE	CENT.
PERFORMANCE	
AIR FLOW (CFM)	1,000
STATIC PRESSURE (IN W.G.)	3.5
FAN SPEED (RPM)	2740
NOISE LEVEL (SONES)	20
MOTOR	
TYPE OF DRIVE	BELT
MOTOR SIZE (HP)	3/4
VOLTS-PHASE-HERTZ	480-3-60
ACCESSORIES	
FAN SPEED CONTROL (NOTE 2)	YES
SPRING ISOLATION	YES

FAN SHALL BE PROVIDED WITH VARIABLE SPEED DRIVE WITH INTEGRAL LINE SIDE DISCONNECT.

AIR DISTRIBUTION DEVICE (DIFFUSERS, REGISTERS AND GRILLES) S) CFM.

MARK	TYPE	FACE SIZE (INCHES)	NECK SIZE (INCHES)	STYLE	COLOR	MATERIAL
S1	SUPPLY DIFFUSER	24x24	SEE TAG	LAY-IN	WHITE	ALUMINUM
S2	SUPPLY DIFFUSER	11-1/8 <b>"</b> ø	SEE TAG	SURFACE	WHITE	ALUMINUM
S3	SUPPLY DIFFUSER	50x8	SEE TAG	SURFACE WITH 1" BORDER	WHITE	ALUMINUM
S4	SUPPLY DIFFUSER	22 <b>"</b> ø	SEE TAG	SURFACE	WHITE	ALUMINUM
S5	SUPPLY DIFFUSER	27 <b>"</b> ø	SEE TAG	ROUND SURFACE	WHITE	STEEL
R1	RETURN GRILLE	24x12	SEE TAG	PERFORATED FACE LAY-IN	WHITE	ALUMINUM
R2	RETURN GRILLE	24×24	SEE TAG	PERFORATED FACE LAY-IN	WHITE	ALUMINUM
R3	RETURN GRILLE	50x8	SEE TAG	SURFACE WITH 1" BORDER	WHITE	ALUMINUM
R4	RETURN GRILLE	50x12	SEE TAG	SURFACE WITH 1" BORDER	WHITE	ALUMINUM
R5	RETURN GRILLE	74×10	SEE TAG	SURFACE WITH 1" BORDER	WHITE	ALUMINUM
R6	RETURN GRILLE	14x12	SEE TAG	SURFACE WITH 1" BORDER	WHITE	STEEL
E1	EXHAUST GRILLE	24x12	SEE TAG	PERFORATED FACE LAY-IN	WHITE	ALUMINUM

AC UNIT (CHILLED WATER) (AC)

MARK		AC-1	AC-2	AC-3	AC-4
SPACE SERVED		CT ROOM	CT ROOM	CT CONTROL ROOM	IT ROOM
AIR HANDLER CONFIGURATION		HORIZONTAL	HORIZONTAL	HORIZONTAL	HORIZONTAL
SUPPLY FAN PERFORMANCE					
AIR FLOW	(CFM)	1,250	1,250	1,000	1,000
OUTDOOR AIR	(%)	0	0	0	0
EXTERNAL STATIC PRESSURE	(IN. W.G.)	0.7	0.7	0.3	0.3
MOTOR SIZE	(HP)	1.5	1.5	0.5	0.5
COOLING PERFORMANCE (CHILLED WATER COI	L)				
TOTAL COOLING CAPACITY	(MBH)	31.0	31.0	26.0	26.0
SENSIBLE COOLING CAPACITY	(MBH)	27.6	27.6	22.8	22.8
ENTERING AIR TEMP. DB/WB	(DEG. F.)	75/62.5	75/62.5	75/62.5	75/62.5
LEAVING AIR TEMP. DB/WB	(DEG. F.)	53.9/52.2	53.9/52.2	53.9/52.2	53.9/52.2
WATER FLOW/PRESSURE DROP	(GPM/FT. HD)	6.0/10	6.0/10	5.0/7.2	5.0/7.2
EWT/LWT	(DEG. F.)	45.0/55.0	45.0/55.0	45.0/55.0	45.0/55.0
ELECTRIC HUMIDIFIER					·
TOTAL CAPACITY	(LB/HR)	4.3	4.3	4.3	4.3
KW		1.5	1.5	1.5	1.5
FILTERS					
TYPE		2" STANDARD	2" STANDARD	4" STANDARD	4" STANDAR
ELECTRICAL DATA - AIR CONDITIONER					
VOLTS-PHASE-HERTZ		460-3-60	460-3-60	460-3-60	460-3-60
FULL LOAD AMPS		5.5	5.5	4.8	4.8
WIRE SIZING AMPS		6.9	6.9	6.0	6.0
MAX. OVERCURRENT PROTECTIVE DEVICE	(AMPS)	15	15	15	15
ACCESSORIES					
MICROPROCESSOR CONTROL WITH WALL M	IOUNTED DISPLAY	YES	YES	YES	YES
RETURN AIRSIDE SMOKE DETECTOR		NO	NO	NO	NO
MANUFACTURER'S STARTUP		YES	YES	YES	YES
FACTORY DISCONNECT SWITCH		YES	YES	YES	YES
SINGLE FLOAT CONDENSATE PUMP		YES	YES	YES	YES
3-WAY CHILLED WATER MODULATING VALV	Έ	NO	NO	YES	NO
HIGH STATIC BLOWER MODULE		YES	YES	NO	NO
2-WAY CHILLED WATER MODULATING VALV	E .	YES	YES	NO	YES
BACnet INTERFACE		YES	YES	YES	YES
REMOTE TEMPERATURE & HUMIDITY SENS	ORS	YES	YES	YES	YES
SUPPLY AIR PLENUM WITH CEILING FASCIA	4	NO	NO	YES	YES
BASIS OF SPECIFICATIONS					
MANUFACTURER		LIEBERT	LIEBERT	LIEBERT	LIEBERT
AIR CONDITIONER MODEL NUMBER		MMD 40C	MMD 40C	MMD 40C	MMD 40C
		(MINI-MATE2)	(MINI-MATE2)	(MINI-MATE2)	(MINI-MATE2

1. UNITS SHALL BE SUPPORTED FROM STRUCTURE WITH THREADED RODS AND VIBRATION ISOLATORS.

		-
Amendment 03	10/21/14 09/12/14 01/17/14	
Amendment 02	09/12/14	
Bid Issue	01/17/14	
	_	4 1

VA FORM 08-6231, OCT 1978

**CONSULTANTS:** 

FREDRICK, FREDRICK & HELLER ENGINEERS, INC. 672 EAST ROYALTON ROAD BROADVIEW HTS., OHIO 44147 TEL. (440) 546-9696 FAX: (440) 546-9699



**ARCHITECT:** 

13212 Shaker Square Suite 204 Cleveland, Ohio 44120 P. 216.752.1800 F.216.752.3833

DESIGN AND CONSTRUCTION DOCUMENTS AS INSTRUMENTS OF SERVICE ARE GIVEN IN CONFIDENCE AND REMAIN THE PROPERTY OF PERSPECTUS ARCHITECTURE. THE USE OF THIS DESIGN AND THESE CONSTRUCTION DOCUMENTS FOR PURPOSES OTHER THAN THE SPECIFIC PROJECT NAMED HEREIN IS STRICTLY PROHIBITED WITHOUT THE EXPRESSED WRITTEN CONSENT OF PERSPECTUS ARCHITECTURE.

FULLY SPRINKLERED Drawing Title Project Number 541-14-101 **HVAC SCHEDULES EXPAND AND RENOVATE NUCLEAR MEDICINE AND** Building Number **RADIOLOGY** Approved: Project Director Drawing Number **VAMC - WADE PARK** 1-H1 Checked DAD BMW 1-17-2014 Dwg.

Office of **Facilities** Management

